

POTENTIAL CONNECTION TO CITY OF SOLVANG WWTP

GUY SAVAGE, LOCSD ADAM DONALD, WSC ALEC BEYERS, CAROLLO

WEDNESDAY, NOVEMBER 13, 2024

POTENTIAL CONNECTION TO CITY OF SOLVANG INFRASTRUCTURE AND WWTP

- Per discussion with City of Solvang, LOCSD hired WSC and Carollo to evaluate existing City of Solvang infrastructure and WWTP
- WSC and Carollo examined engineering feasibility and related costs
- Just because something is feasible from an engineering perspective, does <u>not</u> mean the LOCSD has agreement with the City of Solvang



WASTEWATER PROCESS SIMPLIFIED Source Treatment m Disposal Collection



LOOKING AT COLLECTION MORE CLOSELY





EFFLUENT COLLECTION



GRAVITY FED COLLECTION



IN-DISTRICT COLLECTION COSTS

Approach	Total
Effluent Collection REGEN Option B - entire District	\$ 21,637,095
Gravity Collection South end of District treatment	\$ 27,938,000



TREATMENT AND DISPOSAL



IN-DISTRICT TREATMENT (AND DISPOSAL)

ltem	Estimate
Treatment – 1.5 acre site, Cloacina MBR plant, offices, parking, etc.	\$19,900,000
Disposal - 4 acre site, percolation chambers	\$ 5,200,000
Total	\$25,100,000



LOCAL OPTION

	Effluent Collection	Gravity Fed Collection
Collection	\$ 21,637,095	\$ 27,938,000
Treatment	\$ 19,900,000	\$ 19,900,000
Disposal	\$ 5,200,000	\$ 5,200,000
Total	\$ 46,737,095	\$ 53,038,000





LOCSD TO CITY OF SOLVANG COLLECTION



Images for illustration purposes only, not to scale

WSC CONTRACT CONNECTION TO WWTP

- Examine existing infrastructure (pipes, lift stations, etc.) to determine capacity
- Estimate costs where existing infrastructure insufficient





MODELING CAPACITY

- Baseline Existing Average Existing average annual flow for Solvang only
- Existing Average Existing average annual flow for Solvang with the addition of LOCSD
- Baseline Buildout Average Buildout + infill average annual flow for Solvang only
- Buildout Average Buildout average annual flow for Solvang with the addition of LOCSD
- Buildout + Infill Average Buildout + infill average annual flow for Solvang with the addition LOCSD

IISC



HYDRAULIC MODELING RESULTS

- No pipe segments were identified as over capacity under average annual flow conditions
- Peaking factor of 4.0 was applied to the average dry weather flows to evaluate the peak hour wet weather flow (PHWWF) scenarios for existing and buildout development conditions









MUSC

CONNECTION TO WWTP

- Identified nine projects (see section 4 of TM)
 - Four projects related to sewer mains
 - Five projects related to sewer lift stations
 - Projects not all immediate, some targeted to start 2033
- LOCSD to have a share of \$3,548,630





CAROLLO CONTRACT FEASIBILITY AT WWTP

- Evaluate LOCSD loads and flows on City of Solvang WWTP
- Included look at source drinking water (IDI)

Source	Constituent	ADMMF Flow (gpd)	Avg. Influent Wastewater Concentration (mg/L)	WWTP Influent Load (lb/day)
City of Solvang Wastewater ⁽¹⁾	BOD ₅	713,000	263	2,018
	TSS		201	1,542
	TKN		59	453
LOCSD Phase III Wastewater ⁽²⁾	BOD ₅	133,800	416	451
	TSS		320	347
	TKN		63	68
SYCSD Wastewater ⁽³⁾	BOD ₅	300,000	320	658
	TSS		176	503
	TKN		63	148

Notes:

Abbreviations: gpd = gallons per day; lb/day = pounds per day; mg/L = milligrams per liter; avg = average

(1) WWTP average influent concentrations provided by City of Solvang.

(2) LOCSD estimated wastewater concentrations from 2022 Stantec BODR.

(3) SYCSD wastewater concentrations from 2017 Recycled Water Facilities Plan.



biological oxygen demand (BOD), total suspended solids (TSS), total kjedahl nitrogen (TKN)



CITY OF SOLVANG WWTP

- City of Solvang WWTP is rated to treat 1.5 mgd of influent wastewater flow
- WWTP struggles to meet the effluent limits at current flows due to process limitations (Phase 2 project is intended to address)
- Highly unlikely that the WWTP in <u>its current state</u> would continue to meet permit limits with higher flows from LOCSD

l able 4	Solvang WWTP Effluent Concentrations			
	Constituent	WWTP Effluent Permit Limit (mg/L)	Modelled Effluent Concentration (mg/L)	
	BOD ₅ ⁽¹⁾	30	2.4	
	TSS ⁽¹⁾	20	4.2	
	TN ⁽²⁾	10	8.8	

Notes:

Abbreviations: mg/L = milligrams per liter

(1) 30-day average effluent permit limit provided.

(2) 25-month rolling median effluent permit limit provided.





CONCLUSION: TECHNICALLY FEASIBLE

Post WWTP Phase 2 Upgrades:

- WWTP can effectively meet effluent permit limits while accepting full Phase 3 buildout ADMMF from LOCSD
- Addition of LOCSD wastewater will not affect the ability of the WWTP to meet its effluent permit limits, and the flow rate will not cause the WWTP to exceed its rated capacity
- Carollo does not foresee the background concentrations of TDS, sodium, or chloride in the LOCSD's drinking water (IDI) as negatively affecting the WWTP's ability to meet permit limits for these constituents
- Phase 2 Upgrades Project is currently entering the preliminary design phase and construction is anticipated to be completed in April 2028







WHAT'S NEXT?

- Consider Stantec contract

 LOCSD to Sunny Field Park force main
- Discussion with City of Solvang

Complete cost models

